

Certificate of Compliance

Certificate Number 20060331-R3572
Report Reference 2006 March 31
Issue Date 2006 March 31

Page 1 of 3



Issued to: **Marchfield Door Systems Inc.**
1401 E 4th St
Marchfield, WI 54449


This is to certify that representative samples of **Swinging Type Fire Doors**

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 10B - Fire Tests of Door Assemblies

Additional Information: See addendum for system listings


Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.

Look for the UL Classification Mark on the product

Issued by:

Mona Couloute
Underwriters Laboratories Inc.

Reviewed by:

Matthew Schumann
Underwriters Laboratories Inc.

Certificate of Compliance

Certificate Number 20060331-R3572
Report Reference 2006 March 31
Issue Date 2006 March 31

Page 2 of 3



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Max Rating	Opening Type	Composite Type	Wood Core Type
1-1/2 Hr	Single or Pair Without Astragal Single Point Lock/Flush Bolts	X	
20 Min	Single With Single Point Lock		X
45 Min	Single With Single Point Lock With or Without a Light		X
1-1/2 Hr	Single or Pair Without Astragal Rim, Mortise/Vertical Rod	X	
20 Min	Single With Rim, Mortise		X
1-1/2 Hr	Pair Without Astragal Vertical Rod/Vertical Rod		
1-1/2 Hr	Pair Without Astragal Open Back Strike Provided		
3/4 Hr	Double Egress With Astragal Vertical Rod/Vertical Rod	X	
20 Min	Full Glass Door	X	
20 Min	Dutch Door Single Swing		X
1-1/2 Hr	Door With Automatic Louver	X	
1-1/2 Hr	250 F Temp Rise Door	X	
20 Min	Door Assembly Components Fire Tested w/o Hose Stream	X	

Issued by:
Mona Couloute
Mona Couloute
Underwriters Laboratories Inc.

Reviewed by:
Matthew Schumann
Matthew Schumann
Underwriters Laboratories Inc.

Certificate of Compliance

Certificate Number 20060331-R3572
Report Reference 2006 March 31
Issue Date 2006 March 31

Page 3 of 3



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Max Rating	Opening Type	Composite Type	Wood Core Type
1-1/2 Hr	Standard Pair and Double Egress Pair of Doors with Vertical Rod Less Bottom Rod Type Fire Exit Hardware	X	

Machining for hinges, spring hinges, cylindrical locks, mortise locks, concealed vertical rods, surface vertical rods, concealed vertical rods, surface vertical rods, concealed door bottoms, viewers, pivots, and floor closers.

Vision lites - Std wood moulding kits, metal vision frames and veneer clad molding kits.

Issued by:
Mona Couloute
Mona Couloute
Underwriters Laboratories Inc.

Reviewed by:
Matthey Schumann
Matthey Schumann
Underwriters Laboratories Inc.

Certificate of Compliance

Certificate Number 20060331-R3572A
Report Reference 2006 March 31
Issue Date 2006 March 31

Page 1 of 3



Issued to: **Marshfield Door Systems Inc.**
1401 E 4th St
Marshfield, WI 54449 USA


This is to certify that representative samples of **Swinging Type Fire Doors, Positive Pressure Tested**

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 10C - Standard for Positive Pressure Fire Tests of Door Assemblies


Additional Information: See addendum for system listings

Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.

Look for the UL Classification Mark on the product

Issued by:

Mona Couloute
Underwriters Laboratories Inc.

Reviewed by:

Matthew Schumann
Underwriters Laboratories Inc.

Certificate of Compliance

Certificate Number 20060331-R3572A
Report Reference 2006 March 31
Issue Date 2006 March 31

Page 2 of 3



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Max Rating	Opening Type	Composite Type	Wood Core Type
1-1/2 Hr	Single or Pair with Astragal Single Point Lock/Flush Bolts	X	
20 Min	Single with Single Point Lock		X
45 Min	Single with Single Point Lock With or Without a Light Kit		X
1-1/2 Hr	Single or Pair without Astragal Rim, Mortise/Vertical Rod	X	
20 Min	Single with Rim, Mortise		X
1-1/2 Hr	Pair without Astragal Vertical Rod/Vertical Rod		
1-1/2 Hr	Pair without Astragal Open Back Strike Provided		
3/4 Hr	Double Egress with Astragal Vertical Rod/Vertical Rod	X	
20 Min	Full Glass Door	X	
20 Min	Dutch Door Single Swing		X
1-1/2 Hr	Door with automatic Louver	X	
1-1/2 Hr	250 F Temp Rise Door	X	
20 Min	Door Assembly Components Fire Tested w/o Hose Stream	X	

Issued by:

Mona Couloute
Mona Couloute

Underwriters Laboratories Inc.

Reviewed by:

Matthew Schumann
Matthew Schumann

Underwriters Laboratories Inc.

Certificate of Compliance

Certificate Number 20060331-R3572A
Report Reference 2006 March 31
Issue Date 2006 March 31

Page 3 of 3



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Max Rating	Opening Type	Composite Type	Wood Core Type
1-1/2 Hr	Standard Pair and Double Egress Pair of Doors with Vertical Rod Less Bottom Rod Type Fire Exit Hardware	X	

Machining for hinges, spring hinges, Cylindrical Locks, mortise locks, concealed vertical rods, surface vertical rods, concealed door bottoms, viewers, pivots, and floor closers.

Vision lites - std wood moulding kits, metal vision frames and veneer clad molding kits.

Issued by:
Mona Couloute
Mona Couloute
Underwriters Laboratories Inc.

Reviewed by:
Matthew Schumann
Matthew Schumann
Underwriters Laboratories Inc.